



VSHOOTER VBS1T Report

Machine GUY-19-08-16-13H31





GUY-19-08-16-13H31

Group2F 19-08-16-13H37



Units	mm/s	g	CREST	RPM	deg.C
RV1	12.9	6.69	3.8	1478	-----
RH1	7.5	7.05	4.2	1479	-----
RV3	7.2	0.61	5.3	1478	-----
RH3	8.9	0.91	4.0	1477	-----
AX3	6.6	0.59	5.0	1479	-----



A-MEASURE
UW REFERENTIE IN MEETAPPARATUUR


A-measure bvba | Cuyllitsstraat 94 | B-2018 Antwerpen
info@A-measure.be | www.A-measure.be | 0032(0)475/332.422
BTW BE0652 722 106 | IBAN BE69 3631 6028 6678 | BIC BBRU BEBB

GUY-19-08-16-13H31

Group2F 19-08-16-13H37




Units	mm/s	g	CREST	RPM	deg.C
AX1	6.2	2.32	3.4	1478	-----



GUY-19-08-16-13H31




RV1-V FFT; Max3= H1- F1- F2-



H1-8.9	⊙	
F1-4.4	?	37.1Hz
F2-3.8	?	2.6Hz


RV1-A FFT



GUY-19-08-16-13H31




RH1 -V FFT; Max3= H1- F1- F2-



H1-4.8	⊙	
F1-2.8	?	3.4Hz
F2-2.3	?	12.1Hz


RH1 -A FFT



GUY-19-08-16-13H31




RV3-V FFT; Max3= H1- F1- F2-



H1-5.6	⊙	
F1-1.7	?	100.0Hz
F2-1.4	?	12.5Hz


RV3-A FFT



GUY-19-08-16-13H31




RH3-V FFT; Max3= H1- F1- F2-



H1-7.0	⊙	
F1-2.6	?	12.5Hz
F2-2.2	?	100.0Hz


RH3-A FFT



GUY-19-08-16-13H31




AX3-V FFT; Max3= F1- H1- F2-



F1-4.7	?	12.5Hz
H1-2.4	⊙	
F2-1.4	?	100.0Hz

AX3-A FFT




GUY-19-08-16-13H31



AXI-V FFT; Max3= F1- F2- F3-

F1-3.3	?	12.5Hz
F2-3.0	?	5.6Hz
F3-1.6	?	2.6Hz



AXI-A FFT

